

BIDS AND AWARDS COMMITTEE

BID BULLETIN No. 10 s. 2022

16 May 2022

Project:

Competitive Bidding:

1. Construction of Underground Cabling for FAB Electrical Distribution System (Stage 3)

Date of Bid Opening: 26 May 2022


TO ALL PROSPECTIVE BIDDERS:

No.	Inquiry/Clarifications	Response
1	Based on the previous posting of this project, was Feeder 5 removed along Zones 18, 19 & 23?	Yes.
2	Based on the previous posting of this project, is the FDR 5 LBS (Load Break Switch) in the new drawing Type A?	Yes.
3	For the 10 KVA Transformer, what is primary and secondary voltage for the 3 units?3	For the primary and secondary refer to Section V, No. 13 of the Scope of Works.
4	Is 8281.28 the aggregate point to point length?	Yes.
5	Where is the expanding foam spray applied?	It is applied at all ends of conduit including spare after cable pulling.
6	Is cable jointing the same as cable splicing?	Yes.
7	When all the LBS have been installed, is it possible to energize on the line side first, and then set a schedule for power interruption on the side of the locator?	Yes. We can do this scheme.
8	Will the initial termination be on the line side of the locators' transformers?	No. During the power interruption, all termination shall be accomplished simultaneously.
9	In relation to scheduling the termination, what if the locators cannot give us a schedule or if they do not agree with the schedule?	If the scheduled power interruption was put to halt because the locators did not agree with it, we can suspend the project. However, the remaining works of the project must only be the termination itself.
10	Can the project be suspended for the reason that all the trenches were not backfilled?	If the contractor was not able to backfill all the trenches, the project cannot be suspended because there are still remaining works.
11	Should the BOQ and Detailed Estimate tally?	Yes. The BOQ is in lot while the detailed estimate contains the detailed breakdown of labor equipment and materials with reference to the scope of work and plans for the project.

No.	Inquiry/Clarifications	Response
12	<p><i>One of the financial documents required to be submitted is the latest income and business tax returns filed and paid through the BIR Electronic Filing and Payment System (eFPS). Does this refer in particular to the following documents?</i></p> <p><i>-ITR 2021</i> <i>-VAT 2550-Q (1st Quarter 2022)</i> <i>-1601-EQ (1st Quarter 2022)</i> <i>-0605 Annual Registration (2022)</i></p>	<p>Business Tax Returns refers to the following:</p> <ul style="list-style-type: none"> -Annual Income Tax Returns -Quarterly Income Tax Returns -Monthly Vat Returns -Quarterly Vat Returns -Quarterly Percentage Return; <p>Refer to Sections 3.2 and 3.3 of Revenue Regulation (RR) No. 3-2005.</p>
13	<p><i>What are the latest bid documents for this project?</i></p>	<p>The latest bid documents for this project are those that were uploaded and posted in the PhilGEPS and AFAB Website since 26 April 2022.</p>
14	<p><i>Can an Audited Financial Statement be filed thru eAFS instead of the manual "Received" stamping</i></p>	<p>The submission through electronic Audit Financial Statements (eAFS) pursuant to BIR RMC 49-2020 is acceptable provided that the latest submitted Annual Financial Statement will include the Transaction Reference Number as proof of submission by the bidder in lieu of the manual "Received" stamping.</p>

All terms, conditions and instructions to bidders specified in the Bidding Documents inconsistent with this Bid Bulletin are hereby superseded and modified accordingly.

For guidance and information of all concerned.



CHARLES M. RAMONES

BAC-Chairperson