

**BIDS AND AWARDS COMMITTEE**

**BID BULLETIN No. 12 s. 2022**

**25 June 2022**

Project:

Competitive Bidding:

1. *Upgrading and Replacement of Pad Mounted Transformers to Distribution Type Transformers*

**Date of Bid Opening: 3 August 2022**

TO ALL PROSPECTIVE BIDDERS:

No.	Inquiry/Clarifications	Response
1	<p>Is it possible to use only three secondary bushing for the 25 KVA?</p> <p>Can the required percentage of the ABC for the Single Largest Completed Contract (SLCC) be lowered since the project falls under goods and the delivery is staggered?</p>	<p>Yes.</p> <p>No. The project is considered as non-expendable supplies, and as per Section 23.4.1.3 of RA 9184, the required percentage of the ABC for the SLCC for non-expendable supplies is 50%.</p>

All terms, conditions and instructions to bidders specified in the Bidding Documents inconsistent with this Bid Bulletin are hereby superseded and modified accordingly.

For guidance and information of all concerned.

  
**CHARLES M. RAMONES**

BAC-Chairperson

