

## BIDS AND AWARDS COMMITTEE

### BID BULLETIN No. 1 s. 2024

15 January 2024

Projects:

1. "Collection, Hauling and Disposal of FAB Residual Wastes from Transfer Station to Sanitary Landfill" with PhilGEPS Reference Number 10441302
2. "Construction of Underground Cabling Stage 4 (Take-Over Contract)"

TO ALL PROSPECTIVE BIDDERS:

Item No.	Projects	Clarifications	Response
1	Collection, Hauling and Disposal of FAB Residual Wastes from Transfer Station to Sanitary Landfill	Postponement of bid submission and bid opening schedule.	<p><b>Deadline for Submission of Requests for Clarification</b></p> <p>From: 12 January 2024, 10:00 AM To: 19 January 2024, 10:00 AM Inquiries must be sent via e-mail to the BAC Secretariat (bac.secretariat@afab.gov.ph)</p> <p><b>Bid Submission</b></p> <p>From: 23 January 2024, 9:30 AM To: <u>31 January 2024, 9:30 AM</u> at the Procurement Management Division, Ground Flr., AFAB Administration Building, FAB, Mariveles, Bataan</p> <p><b>Bid Opening</b></p> <p>From: 23 January 2024, 10:00 AM To: <u>31 January 2024, 10:00 AM</u> at the Board Room, 2/F, AFAB Administration Building, FAB, Mariveles, Bataan and via Google Meet: <a href="https://meet.google.com/vxk-iztv-vqh">https://meet.google.com/vxk-iztv-vqh</a></p>




Item No.	Projects	Clarifications	Response
2	<i>Construction of Underground Cabling Stage 4 (Take-Over Contract)</i>	Postponement of bid submission and bid opening schedule.	<p><b>Deadline for Submission of Requests for Clarification</b>  From: 12 January 2024, 10:00 AM  To: 19 January 2024, 10:00 AM  Inquiries must be sent via e-mail to the BAC Secretariat (bac.secretariat@afab.gov.ph)</p> <p><b>Bid Submission</b>  From: 23 January 2024, 1:00 PM  To: <u>31 January 2024, 1:00 PM</u> at the Procurement Management Division, Ground Flr., AFAB Administration Building, FAB, Mariveles, Bataan</p> <p><b>Bid Opening</b>  From: 23 January 2024, 1:30 PM  To: <u>31 January 2024, 1:30 PM</u> at the Board Room, 2/F, AFAB Administration Building, FAB, Mariveles, Bataan and via Google Meet: <a href="https://meet.google.com/vxk-iztv-vqh">https://meet.google.com/vxk-iztv-vqh</a></p>
3		Request to extend contract duration from 90 calendar days to 120 calendar days due to Foreign Procurement of Cables and LBS.	Contract duration shall be extended from ninety (90) calendar days to one hundred twenty (120) calendar days for the following reasons: customs processing, possible repair of existing cable ducting, delivery of imported materials.
4		Documents for submission and verification during post-qualification (Bidder's own format)	1. Construction schedule and S-curve; 2. Manpower schedule; 3. Construction method; 4. Equipment utilization schedule; 5. Certificate of Site Inspection (to be provided by the end-user unit upon conduct of site inspection); and 6. Other documentary requirements to be submitted by the bidder as required in Item III.1, III.2 and III.3 of the Specifications
5		When shall the cash flow by quarter be submitted?	This shall be submitted during bid submission.

Item No.	Projects	Clarifications	Response
6	<i>Construction of Underground Cabling Stage 4 (Take-Over Contract)</i>	Hierarchy of documents	1. Contract 2. Bid Bulletin 3. Philippine Bidding Documents 4. Specifications 5. Plans & Drawings 6. Submitted Bill of Quantities 7. Submitted Detailed Estimate
7		Submission of DOLE approved Construction Safety and Health Program	To be submitted by the winning contractor upon issuance of Notice to Proceed and prior to actual implementation.
8		Request for Mandrel Probing of already existing and installed cable ducts.	Prospective bidders are allowed to have the Mandrel Probing.
9		If Mandrel Probing of existing cable ducts is clogged or dented, is the repair/rectification eligible for a variation order?	No.
10		For clarification: Outage/ Tapping will be once and a maximum of twice only.	The contractor is limited to a maximum of two (2) power interruption/s. The contractor can request for additional power interruption subject to the approval of AFAB.
11		For clarification: Security during construction, cabling and energization shall be by AFAB.	Security shall be informed by the Freeport Facilities Department to the Public Safety and Security Department. However, the winning contractor shall have the full responsibility in ensuring that all materials, property and equipment in the construction site are secured and properly guarded.
12		Can a bidder with PCAB License Category under Category B, Size Range Small B Specialty in Electrical works still participate in the bidding?	Yes.

Item No.	Projects	Clarifications	Response
13	Construction of Underground	Regarding the SLCC, can bidders use any electrical project?	The SLCC shall include underground cabling.
14	Cabling Stage 4 (Take-Over Contract)	For clarification: The contractor's responsibility will be up to tapping of loads only. Any addition or improvement on service poles (i.e. Fuse cut-out, pin insulators, cross arms are excluded) shall be by AFAB.	No. For this project, the improvement of service poles shall be done by the winning contractor.

This Notice is issued in accordance with Section 29 of the Revised Implementing Rules and Regulations of Republic Act. No. 9184.

For guidance and information of all concerned.

  
**PERCIVAL B. PERALTA**  
 BAC-Chairperson